

Job Name/Location:

Tag #:

Date:

For:	File	Resubmit
	Approval	Other _____

PO No.:

Architect:

GC:

Engr:

Mech:

Rep:
(Company)

(Project Manager)



PQSH1201

Outdoor Unit Drain Pan Heater



Electrical:

Power Requirements	Wiring Harness Plugs into Outdoor Unit Control Board Terminal
Control Requirements	Wiring Harness Plugs into Outdoor Unit Control Board Terminal
Capacity (W)	120W

Compatibility:

Single-Zone Art Cool™ Mirror Outdoor Units: LSU180HSV5, LAU240HSV3; Single-Zone High Efficiency Outdoor Units: LSU180HSV5; Single-Zone Extending Piping Outdoor Units: LSU303HLV, LSU363HLV.

Notes:

1. Follow all installation instructions in the Base Pan Heater Installation manual.
2. Ensure that there is at least 1-3/16" clearance from the outdoor unit fan.
3. As a safety precaution, the heater will not energize if the outdoor temperature is higher than 32°F.
4. To determine the date of the outdoor unit manufacture, refer to the first three digits of the serial number. First digit represents the year; second and third digits represent the month. For example, SN 503XXXXXX indicates date of manufacture of March 2015.
5. Appearances may vary depending on model.

